

CERTIFICATE

Certificate holder

APATOR METRA s.r.o.
Havlickova 919/24
787 01 Šumperk
CZECH REPUBLIC

Product

Heat cost allocators - Appliances with electrical energy supply

Type, Model

E-ITN 40

Testing basis

DIN EN 834:2017-02
Certification scheme Heat cost allocators (2017-04)

Mark of conformity**Registration No.**

298/20 E

Valid until

2025-07-31

Right of use

This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number.

See annex for further information.

2020-12-17

C. Seiser
Dipl.-Phys. Carlo Seiser
Head of Certification Body



ANNEX

Page 1 of 1

Certificate

298/20 E dated 2020-12-17

Technical Data

Models: E-ITN 40.xx, E-ITN 40.xx EX with external sensor

Type: compact device with local, separate-action measuring sensors, two-sensor measuring method

Readout of measured values: Decentralized

Upper temperature limit $t(\max)$: 105 °C

Lower temperature limit $t(\min)$: 35 °C

Basic state: $t_m = 50$ °C

**Testing laboratory/
Inspection body**

Strojírenský zkušební
ústav, s.p. (SZU)
Hudcova 424/56b
621 00 Brno 21
CZECH REPUBLIC

Test report(s)

39-14337/T dated 2020-07-27

