



**CERT**

# DVGW type examination certificate

## DVGW-Baumusterprüfzertifikat

**DW-4715DM0622**  
Registration Number  
Registriernummer

<b>Field of Application</b> <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
<b>Owner of Certificate</b> <i>Zertifikatinhaber</i>	Apator Powogaz S.A. ul. K. Janickiego 23/25, PL-60-542 Poznan
<b>Distributor</b> <i>Vertreiber</i>	Apator Powogaz S.A. ul. K. Janickiego 23/25, PL-60-542 Poznan
<b>Product Category</b> <i>Produktart</i>	flow meters: Water flowmeters (4715)
<b>Product Description</b> <i>Produktbezeichnung</i>	Water flowmeters
<b>Model</b> <i>Modell</i>	JS SMART
<b>Test Reports</b> <i>Prüfberichte</i>	type testing: 2-0096/21 from 25.08.2021 (TZW) UBA-Guideline: K-279399-16-Bs/st from 22.12.2016 (WHY) hygienic testing: W-281886e-17-SI/ni from 20.02.2017 (WHY) UBA-Guideline: K-281196-17-Bs/st from 14.02.2017 (WHY) hygienic testing: W-291948e-17-SI/to from 24.11.2017 (WHY) UBA-Guideline: K-320616-19-Ko/st from 12.11.2019 (WHY)
<b>Test Basis</b> <i>Prüfgrundlagen</i>	DVGW W 421 (01.05.2009) UBA BWGL-Metalle (14.05.2020) UBA ELASTOM (16.03.2016) UBA Übergangsregelung KTW-BWGL (10.07.2020) DVGW W 270 (01.11.2007)
<b>Date of Expiry / File No.</b> <i>Ablaufdatum / Aktenzeichen</i>	25.08.2026 / 20-0310-WNE



13.12.2021 GI A-1/2

Date, Issued by, Sheet, Head of Certification Body  
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



Deutsche  
Akkreditierungsstelle  
D-ZE-16028-01-05

DVGW CERT GmbH  
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3  
53123 Bonn

Tel. +49 228 91 88 - 888  
Fax +49 228 91 88 - 993

www.dvgw-cert.com  
info@dvgw-cert.com

<b>Type</b> <i>Typ</i>	<b>Technical Data</b> <i>Technische Daten</i>	<b>Remarks</b> <i>Bemerkungen</i>
JS SMART+ / JS SMART C+	pressure rating: PN 16 nominal diameter: DN 15 flow capacity: 2,5 m <sup>3</sup> /h	Construction length: 110 mm
JS SMART+ / JS SMART C+	pressure rating: PN 16 nominal diameter: DN 20 flow capacity: 2,5 / 4,0 m <sup>3</sup> /h	Construction length: 130 mm

<b>Type Variation</b> <i>Ausführungsvariante</i>	<b>Explanations</b> <i>Erläuterungen</i>
JS Smart+	R80 or R100
JS Smart C+	R160